

City of Medina

TTHM Stage 2 DBP Rule
Locational Running Annual Averages

DATE	SITE 1	LRAA	SITE 2	LRAA	SITE 3	LRAA	Site 4	LRAA
8-Mar-12	28.0		25.7		27.4		30.6	
9-Jun-12	39.8		36.0		39.0		37.9	
12-Sep-12	64.8		61.2		58.1		56.8	
13-Dec-12	27.3	40.0	27.3	37.6	31.6	39.0	40.2	41.4
14-Mar-13	20.1	38.0	19.4	36.0	21.9	37.7	22.0	39.2
10-Jun-13	41.0	38.3	35.5	35.9	40.6	38.1	52.9	43.0
11-Sep-13	57.4	36.5	49.2	32.9	50.0	36.0	61.4	44.1
10-Dec-13	32.1	37.7	30.7	33.7	30.5	35.8	33.0	42.3
10-Mar-14	24.8	38.8	24.1	34.9	24.3	36.4	25.5	43.2
11-Jun-14	51.3	41.4	46.9	37.7	50.1	38.7	57.1	44.3
13-Sep-14	62.7	42.7	69.7	42.9	78.3	45.8	107.4*	28.9
10-Dec-14	29.5	42.1	26.4	41.8	26.1	44.7	32.8	28.9
10-Mar-15	24.5	42.0	21.2	41.1	22.5	44.3	27.0	29.2
10-Jun-15	43.4	40.0	39.0	39.1	41.8	42.2	47.0	26.7
8-Sep-15	53.0	37.6	58.1	36.2	49.5	35.0	63.5	42.6
8-Dec-15	36.6	39.4	33.7	38.0	31.7	36.4	41.6	44.8
9-Mar-16	45.6	44.7	32.6	40.9	32.9	39.0	35.6	46.9
8-Jun-16	54.8	47.5	54.8	44.8	60.7	43.7	67.9	52.2
14-Sep-16	71.8	52.2	60.2	45.3	55.2	45.1	72.1	54.3
14-Dec-16	27.7	50.0	23.7	42.8	25.0	43.5	29.1	51.2
8-Mar-17	38.8	48.3	38.9	44.4	39.3	45.1	45.0	53.5
13-Jun-17	47.6	46.5	49.3	43.0	45.5	41.3	53.6	50.0
13-Sep-17	58.8	43.2	56.8	42.2	51.6	40.4	58.0	46.4
12-Dec-17	30.9	44.0	30.6	43.9	31.6	42.0	35.8	48.1
12-Mar-18	31.0	42.1	28.6	41.3	27.9	39.2	29.3	44.2
12-Jun-18	56.0	44.2	54.8	42.7	54.9	41.5	67.1	47.6

- Site 1 300 W Reagan Parkway
- Site 2 1010 Lafayette Rd
- Site 3 S. Court Tank
- Site 4 100 High Point Dr.

*Operational changes instituted in preparation of painting S Court Tank interior resulted in a more than usual tank turnover leading to a high result.